WVC-600 micro inverter WiFi/433MHz Version User manual



WVC600-433/WiFi **Micro inverter**



	, ,			
model	WVC600-R3-433/WiFi			
Maximum input power	700Watt			
Output voltage mode	120/230V Auto switch			
PV Open circuit voltage	30-60VOC	30-60VOC		
Operating voltage range	22-60V	22-60V		
Starting voltage range	22-60V			
short-circuit current	30A			
Maximum working current	24A			
Output parameters	@120V	@230V		
Output peak power	700Watt	700Watt		
Rated output power	600Watt	600Watt		
Output current	5A	2.6A		
AC voltage range	80-160VAC	180-280VAC		
AC frequency range	48-51Hz/58-61Hz	48-51Hz/58-61Hz		
Power factor	>95%	>95%		
Number of branch connections.	6PCS (Single)	12PCS (Single)		
Output efficiency	@120V	@230V		
Static MPPT efficiency	99.5%	99.5%		
Max output efficiency	95%	95%		
Loss of power at night	<0.5W <0.5W			
Total current harmonics	<5% <5%			
Appearance and tech	nical features			
Temperature range	-40°C to +65°C			
Size (L×W×H)	283mm×200mm×41.6mm			
Net amount	1.56kg			
Waterproof grade	Ip65 NEMA3R			
Heat dissipation mode	Self-cooling			
Communication mode	433MHz/WiFi			
Power transmission mode	Reverse transmission, Load priority			
monitoring system	Mobile phone APP、Browser			
electromagnetic compatibility	EN50081.part1 EN50082.Part1.CSA STD.C22.2 No.107.1			
Power grid	EN61000-3-2 EN62109.UL STD.1741			
Power grid detection	DIN VDE 0126 IEEE STD.1547.1547.1 and 1547.A			
certificate	CEC , CE , INMETOR , ETL , Patented technology			
Packing weight				
Specifications	Each (Packing)	Box (5PCS)		
weight	2.8 K G	14 K G		
Size	342×240×115mm	440×380×260mm		

Features

- Maximum power point tracking Adaptive voltage/frequency
- Reverse power transmission
- I / O, fully isolated
- Multiple parallel stacks


Parameter

Internal high precision meter
 Forward full-bridge topology


• 5G Iot Platform management

• Voltage mode microgrid


- App monitoring system
- No installation, no maintenance



Appearance description of micro inverter



Description of the connector and cable core of the micro inverter



LED indicator function of micro inverter

1.Red light is on---The micro-inverter is powered on, the red light is on, and the equipment is ready to work;

2.Red light flashes----The micro-inverter is fully prepared and enters the delayed startup state;

3. Flashing green-----MPPTMaximum power point search status;

4.Green light is on----MPPTMaximum power point locked state;

5.The green light turns red----a.Island protection; b. Frequency protection; c. AC over/under-voltage protection; d. DC voltage over and under voltage protection; e. fault; f. software shutdown;

Normal working indicator flashing process:

Connect the micro-inverter to the AC and DC terminals, and then turn on the power \rightarrow the red light will be on for 3 seconds \rightarrow the red light will flash for 30 seconds \rightarrow the green light will flash quickly (MPPT maxim um power point search) \rightarrow The green light is on, (MPPT lock).

433MHz Long distance communication

The communication method of 433MHz is a short connection method, that is, the signal is disconne -cted after sending / receiving. The device for data collection with the inverter is WiFi-MODEM. The communication channel is civilian channel. Long-distance wireless transmission (open area up to 1800 meters, good wall penetration capability, air baud rate 500bps) Operating frequency range (433.4-473.0MHz, up to 100 communication channels) Maximum 100mW (20dBm) transmit power 8 levels of power can be set) Four working modes, suitable for different applications, please refer to the WiFi-MODEM instruction manual for specific usage details.




Power monitoring system diagram



WiFiData collector usage settings

1、Preparation for use:


If you want to use the monitoring system of WVC series micro-inverters, you must install and set up WVC series WiFi data collector. WiFi data collector is the data exchange bridge of WVC series micro-inverters. It is in the micro-inverter and mobile APP, The function of data collection and data exchange between computers, using 433MHz signal to send the voltage, current, temperature, power and other data of the micro-inverter to the KDM server via WiFi signal, mobile APP / computer can smoothly monitor the power generation data of the power station , Ple -ase connect the antenna and power cable of the data collector as shown on the right.



WiFi Modem hardware connection diagram


2、APP Phone Settings :

A) Please visit our company's official website to download the kaideng-app.apk app and install it on your Android phone, then click the Kaideng app to enter the login interface, then click the collector to initialize.As shown in Figure 1:




B) As shown in Figure 2, click the red circle to select HF-A11x_AP in the AP SSID of the collector, click thecompany WiFi SSID to select the WiFi network name in your home, and enter the password in the WiFi password.

C) After all are entered, first select the drop-down menu of the mobile phone and long press the network to select the HF-A11x_AP connection, as shown in Figure 3, and close the data connection of the mobile phone, as shown in Figure 4:



D) After all are entered, first select the drop-down menu of the mobilephone and long press the network to select the HF-A11x_AP connection, as shown in Figure 3, and close the data connection of the mobile phone, as shown in Figure 4:



E) Most smartphones automatically select a network. When the connected network pops up and there is no Internet access signal, be sure to choose to keep connected to ensure that the initialization is carried out smoothly, as shown in Figure 5, and the initialization is completed at the last point, as shown in Figure 6 As shown.

Note: Because HF-A11x_AP is not connected to the Internet, the Android phone will automatically disconnect the network, which will make our initialization unsuccessful. Please find the automatic switching functionin the Android phone's system settings and turn it off.

3、Computer Settings :

A) Click on the computer to connect to the WiFi network of HF-A11x_AP as shown in Figure 8, open the browser in the computer, enter the IP address: 10.10.100.254, enter in the name: admin, enter in the password field: admin.

As Shown in Figure 9:

ľ

第 HF-A11x_AP 1 开放 其他人可能会看到你通过此网络发送的信息 ✓ 自动连接 2	服务器 10.10.100.254 将要求你输入用户名和密码。服务器报 告它来自 A11。 警告:将在不安全的连接上使用基本身份验证发送你的用户名 和密码。
道線 旋線 参会	admin 1
Figure8	□ 记住我的凭据 3 确定 取消

Figure9

- 1、Select STA mode on Mode Selection, as shown in Figure 10:
- $2\$ Click Search on the STA Interface Setting to search the network as shown in Figure 11:

Mode Selection 1	Working Mode Configuration	Mode Selection AP Interface Setting STA Interface Setting	STA Interface Setting You could configure STA interface parameters here.		
STA Interface Setting Application Setting Device Management	Access Point TA Mode: Station Mode Deta Transfor Mode Data Transfor Mode	 Application.Setting Device Management 	5TA Interface Parameters AP> SSID SEAC Address (Optimal) Security Mode Encryption Type	HF-Alls_H 2 Search	
Fi	gure10		3 WAN COMPETER	National Activity of the Internet of the Internet	

3、Select your own network in the searched network list as shown in Figure 12:


4、Click Search on the STA Interface Setting to search the network, and enter the password in the Pass Phrase and click Apply, as shown in Figure 13:

_												
٠	saidens 1	24 00 33 10 12 24			48.9	WPA2PSK	and a advantage	(
0	Charafiel vOltri	\$4.66 Sc 72 17 49			TIOP	WPA2PSK	Infrastructure					
0	Constitut-4205	48.07.32.30.09.15			TKEP	WPA2PSK	Infrastructure	Mode Selection		STA Interface Set	ing	
0	Charafiel 15	el 10 26 20 x4.30			AES	VIPAZPSK	left øste utture	Herman March 1997				
	5548	48 3a 35 08 41 41			AES	VIF#2PSK	Billastructure	AP Interface Setting				
2	10152635	74.61.829.64.35			443	WPA3PSK	W/rastructure		You could configure STA interface parameters here.			
2	Charaket-AmSH	od Stimitae Ut 54			THIF	WFA2PSK	Biffastructure	STA Interface Setting	1			
2		et 3ctb 64/32/78			A£9	WPA2PSK	whatesteet	and the second sec		STA Interface Parameters		
2	@PHICOMM_20 25Y301				TKOP	WP42P0K	web3.92m/ture	Application Setting		AP's SSID	kaideng	Search
è	TP LINK, FIM	No BE SHOT A			AES		whattuiture			C	his only	Line Cold To
2	TP-UNK_EBS	d2.5x 10.64 x07.50			AES	WPA3P9K	MASSfruiture Meredruiture	Device Management		MAC Address (Optional)		
5	SPECURY SNT	44 11 15 32 55 32			LACT .	WEATHSK	add astroniture			Security Mode	WPA2PSK V	
5	4836	All en Tic municipal			AES.	VPA2PSK	N/I ANTI-LITER					
2	Chastial-GCF	18.52.82.54 11.24	15	13	AES	WPA2PSK	W/rastrocture			Encryption Type	AES 🗸	
0	*****	bc 54 ft:102 ac 50	15	11	AES	W#A2PSK	Infrastructure			Pass Phrase	kaideng168	3
4	plr. Bornah	3										*
										4	Apply Ca	ancel
Figure12							WAN Connection	ype:	[DHCP (Auto config) >			
riguiciz					DHCP Mode							

Figure13

5、In Application Setting, select Mode as Client> enter Port 1234> enter Server Address 47.115.28.119> click Apply to confirm as shown in Figure 14:

6、Restart the device in Device Management to complete the settings as shown in Figure 15:



WVC Series micro inverter

4、Use of APP:

Please visit our company's offici -al website to download the kai -deng-app.apk app and install it on your Android phone, then cli -ck the Kaideng app to enter the login interface, click to register a new account, then click to log in to the power station interface and click Add Power Station As shown on the right.

100 2019-00-00 2019-00-00 2019-00-10 2019-00-10 2019-00-10 1010 2020-00-10 2020-00-10 2020-00-10 2021-00-00 2021-00-00
a Inija 1510 2020-04-15
lick here.



Add the inverter to the inverter addition page, enter the inverter code in the Inve -rter Code field, and then click Single Add to complete the addition of the inverter, as shown on the left

 Station Name:

 Station Name:

 Station Name:

 Demol

 Station Name:

 China

 Data Address:

 China

 Data Statistics


 Data Statistics

Address information Please enter each item related to the power station, select "No" in the opt 'No' must be entered here Found behind the collector '1' must be entered here the collector, enter "1" in the calcula Fill in the actual installed capacity Click here to complete

The pictures on the right are "In -verter Data Detail Page" and "I -nverter List Page". To view the data details of a single inverter, click the icon in the inverter list to open the inverter data Details.

Cinverter List)
Netter Temperatur(1) 11
Constructure 1.24 Wang(XXX) 234 Microsoft 234 C Time C Tim

4. Immediately monitor your power plant and keep track of your power plant data :



WVC series micro-inverter installation guide

To properly install and use WVC series micro inverters, please read and follow this guide and all warnings and ins -tructions in Kay Energy WVC micro inverters. The "Installation and Operation Manual" can be downloaded from the official w -ebsite of Kaden Energy: www.kaidengdg.com.Safety warnings are listed on the back of this guide. All models of WVC Series Mic -ro inverter listed in this guide have a ground wire in the AC cable, no additional ground electrode is required(EGC), there are thr -ee wires in-side the AC cable with equipment, which are Blown zero line N (Blue) ground wire / safety line G (Yellow & green). Ea -ch micro-inverter is equipped with an AC cable with a length of 3 * 4 * 2 meters. The current of each AC cable branch cannot be greater than 40A. For the number of connected branches of each branch, refer to the following installat-ion guide. **Important information:** WVC series micro-inverters use IP65 waterproof rating. When installing, please try to install it in a place where there is no rain, nor in a place where the sun is exposed to ensure ventilation and heat dissipation.

Preparation before installation:

 Please visit our company's official website to download the kai-deng -app.apk app to install on your And -roid phone, then open the app and regis -ter an account on it, and create a power station on the account to reverse the WVC series. The inverter is monitored or contro -lled. For detailed operation, please refer to the instructions in the inverter monitor -ing section.



- 2、The device for data collection with the inverter communication is WiFi-MODEM, and the communication method between WiFi -MODEM and inverter is long-distance wireless transmission (o -pen field 1800 meters, air baud rate 00bps). Operating frequen -cy range (433.4-473.0MHz Up to 100 communication channels) Maximum 100mW (20dBm) transmit power (8 levels of power can be set) Four working modes, suitable for different applications, please refer to the WiFi-MODEM manual for details.
- 3、Please refer to the following list and compare the electrical par -ameters of the solar modules in the table to select the inverter model.

Inverter model	Connector	Photovoltaic module
WVC-295	1*MC4	
WVC-300	1*MC4	
WVC-350	1*MC4	The number of mat
WVC-600	2*MC4	-ched photovoltaic modules is 60 strin
WVC-700	2*MC4	-gs / 72 strings / 90
WVC-1000	2*MC4	strings. The open c -ircuit voltage Voc
WVC-1200	4*MC4	is between 30-60V
WVC-1400	4*MC4	
WVC-1600	4*MC4	
WVC-2000	4*MC4	


- 4. In addition to Kaideng Energy's WVC series micro-invert -ers, you must also purchase photovoltaic brackets / AC boxes / electrical cables and other related materials. The current of each channel of the WVC series micro-inverte -rs at the branch of the installed circuit cannot exceed 40 Amp, if the rated current is exceeded, it may lead to an un -safe factor.
- 5. Check if you still have the following related equipment: AC junction box, tools: screwdriver, wire cutter, voltmeter, tor -que wrench, socket and wrench for installing hardware, etc.

- 6. After the installation of the power station is completed, ple -ase install a ground wire on the photovoltaic support, inst -all and use a lightning protection and / or surge suppress -ion equipment protection system in the AC junction box. It is very important to have a switch device that automatically protects against lightning strikes and surges.
- 7. When installing the inverter handshake cable, please plan th -at your AC branch circuit cannot exceed the current limit, so that the maximum number of micro-inverters in each branch can be reasonably allocated.

Inverter model	Number of branches
WVC-295	30PCS
WVC-300	30PCS
WVC-350	25PCS
WVC-600	15PCS
WVC-700	12PCS
WVC-1000	10PCS
WVC-1200	8PCS
WVC-1400	6PCS
WVC-1600	5PCS
WVC-2000	5PCS


*Each region may be different. Please refer to local requirem -ents to define the number of micro-inverters per branch in your area.

- 8、Implement all national electrical codes (NEC), ANSI / NFPA 70 in accordance with all local electrical codes and all relev -ant regulations.
- 9. Please note that only qualified personnel can install and / or replace Kaideng micro-inverters.
- 10, Please do not try to repair Kaideng micro-inverter. It does n -ot contain user-serviceable parts. If it fails, please contact Kaideng customer service to obtain the ID number and start the replacement process. Tampering or opening the Kaideng micro inverter will invalidate the warranty.
- 11, Before installing or using Kaideng Micro Inverter, please rea -d all instructions and technical instructions and the warning mark system and photovoltaic array on Kay Microinverter.
- 12. Please make sure that the installation operation is performed before the AC power is disconnected, and do not install the K -aideng micro-inverter with power on.
- 13, Please install Kayden micro inverter series products as shown in the following figure.





Inverter installation steps

Step1 Install the inverter on the bracket of the photovoltaic panel with the screws pro-vided with the machine, as shown in the fo -llowing figure:



Step2 Connect the positive and negative poles Step3 Open the waterproof cover of the AC output of the DC connection MC4 plug on the photovo connector of the inverter and connect the AC cable -Itaic board to the DC input terminal of the inv -erter, as shown below:





Step 4 Connect the AC output cable to the AC main cable;

Step 5 Repeat steps 1 to 3, install and connect all inverters;


Step 6 Connect the AC main cable to the utility grid to start your green energy journey.

to the AC waterproof plug. The connection method

is as shown in the plug connection diagram:

Note: Before installing WVC series micro inverter products, please read this manual and pay attention to the installation details.

This manual contains important instructions that should be followed when installing and maintainingReduce the risk of electric shock and ensure safe installation and ope -ration of Kaideng MicroInverters, Always follow the following safety symbols present in this document to indicate hazardous conditions and important safety Instructions.



Wiring Diagram WVC-600 Triple Phase